

Tabuľka č. 7 - Návrh transformačných staníc

UPC	FPB	Funkčné využitie územia	merná jednotka		NO	VO	NO
			bytová a ubytov. Jednotka	podlaž. plocha v m2	r. 2030	r. 2045	r. 2030
1	2	3	4	5	Pp v kW	Pp v kW	TS/výkon (kVA)
1	2	3	4	5	9	10	11
1 – Bystričany							
1	1.1	OÚ / IBV	35		138,60	-	
	1.1	OV / RÚ		1 863	74,52	-	
	1.2	OÚ / IBV	10		49,50	-	
	1.3	OÚ / IBV	26		102,96		1x630
	1.4	OÚ / IBV	19		75,24		
	1.5	OÚ / IBV	19		75,24		
	1.18	RÚ / INT		5 805	185,76	-	
	1.19	OÚ / IBV	8		42,24	-	
				Σ	744,06		
	1.6	VÚ / PRV		5 069	202,76	-	
	1.15	V-PO		5 702	182,46	-	1x630
	1.23	OÚ / IBV	9		52,47		
	1.24	OÚ / IBV	9		52,47	-	
				Σ	490,16		
	1.7	VÚ / PDTZ		5 530	221,20		1x360
	1.8	VÚ / PRV		1 498	59,92	-	exist.
	1.9	VÚ / PRV		66 960	1 607,04	-	3x630
	1.10	VÚ / PRV		156 845	3 764,28	-	4x1000
	1.12	RÚ / INT		30 931	742,34		1x630
	1.20	VÚ / POV		5 587	178,78	-	1x360
	1.13	RÚ / INT		8 395	268,64		1x400
	1.14	RÚ / INT		11 664	373,25	-	1x400
	1.17	OÚ / IBV	5		30,80		exist.
	1.11	RÚ / INT		6 394	255,76	-	1x630
	1.21	RÚ / INT		5 724	183,17		
				Σ	438,93		
	1.22	RÚ / EXT		0	-	0,00	-
2 – Chalmová							
2	2.1	RÚ / INT		6 048	241,92		
	1.16	RÚ / INT		3 701	148,04	-	1x630
	2.2	OÚ / IBV	7		39,27		
				Σ	429,23		
	2.3	RÚ / INT		2 722	108,88		exist.
	2.4	RÚ / INT		3 758	150,32		
	2.5	RÚ / INT		8 035	321,40		
	2.6	RÚ / INT		7 225	289,00		
	2.7	VÚ/PDTZ		0	0,00	-	2x630
	2.8	VOD.NÁDRŽ		0	0,00		
	2.9	OÚ / INT		8 317	266,14		
				Σ	1 026,86		
	2.10	RÚ / EXT		0	-	0,00	
3 – Vieska							
3	3.1	OÚ / IBV	10		49,50		
	3.2	OÚ / IBV	4		14,52		
	3.3	VÚ / PRV		4 234	169,36		1x360
	3.4	VÚ / PRV		1 296	51,84		
	3.5	POH		0	-		
	3.6	VÚ / VSÚ*		864	51,84		
	3.7	RÚ / EXT		0	-	0,00	
				Σ	337,06		