

Aktualizácia 2016

Tabuľka č. 7 - Návrh transformačných staníc

| UPC | FPB  | Funkčné využitie územia | merná jednotka                  |                             | NO<br>r. 2030 | VO<br>r. 2045 | NO<br>r. 2030                    | NO<br>r. 2030                        |
|-----|------|-------------------------|---------------------------------|-----------------------------|---------------|---------------|----------------------------------|--------------------------------------|
|     |      |                         | bytová a<br>ubytov.<br>Jednotka | zastavaná<br>plocha<br>v m2 | Pp v kW       | Pp v kW       | TS<br>navrhovaná/<br>výkon (kVA) | TS<br>rekonštruovaná/<br>výkon (kVA) |
| 1   | 2    | 3                       | 4                               | 5                           | 9             | 10            | 11                               | 11                                   |
|     | 1.1  | OÚ / IBV                | 24                              |                             | 103           |               |                                  |                                      |
|     | 1.2  | OÚ / IBV                | 13                              |                             | 64            |               |                                  |                                      |
|     |      |                         |                                 | Σ                           | 167           |               | TSN1 1x250                       |                                      |
|     | 1.3  | OÚ / IBV                | 25                              |                             | 107           |               |                                  |                                      |
|     |      |                         |                                 | Σ                           | 107           |               |                                  | TS6 250/400                          |
|     | 1.4  | VÚ / PRV                | 26                              |                             | 112           |               |                                  |                                      |
|     | 1.4  | VÚ / PRV                |                                 | 7 032                       | 352           |               |                                  |                                      |
|     |      |                         |                                 | Σ                           | 463           |               | TSN2 1x400                       |                                      |
|     | 1.5  | OÚ / IBV                | 2                               |                             | 17            |               |                                  |                                      |
|     |      |                         |                                 | Σ                           | 17            |               |                                  | TS1 bez zásahu                       |
|     | 1.6  | OÚ / IBV                | 8                               |                             | 45            |               |                                  |                                      |
|     |      |                         |                                 | Σ                           | 45            |               |                                  | TS4 160/250                          |
|     | 1.7  | OÚ / IBV                | 10                              |                             | 53            |               |                                  |                                      |
|     | 1.8  | RÚ / INT                |                                 | 2 280                       | 57            |               |                                  |                                      |
|     | 1.9  | OÚ / IBV                | 7                               |                             | 41            |               |                                  |                                      |
|     | 1.19 | OÚ / IBV                | 4                               |                             | 27            |               |                                  |                                      |
|     |      |                         |                                 | Σ                           | 178           |               | TSN4 1x250                       |                                      |
|     | 1.10 | OÚ / IBV                | 19                              |                             | 88            |               |                                  |                                      |
|     | 1.17 | OÚ / IBV                | 11                              |                             | 57            |               |                                  |                                      |
|     | 1.18 | OÚ / IBV                | 23                              |                             | 101           |               |                                  |                                      |
|     |      |                         |                                 | Σ                           | 246           |               |                                  | TS8 250/630                          |
|     | 1.14 | OÚ / IBV                | 25                              |                             | 107           |               |                                  |                                      |
|     |      |                         |                                 | Σ                           | 107           |               | TSN5 1x160                       |                                      |
|     | 1.15 | OV                      |                                 | 450                         | 11            |               |                                  |                                      |
|     |      |                         |                                 | Σ                           | 11            |               |                                  | TS5 bez zásahu                       |
|     | 1.16 | OÚ / IBV                | 12                              |                             | 61            |               |                                  |                                      |
|     |      |                         |                                 | Σ                           | 61            |               |                                  | TS3 250/400                          |
|     | 1.11 | OÚ / IBV                | 6                               |                             | 36            |               |                                  |                                      |
|     | 1.12 | OÚ / HBV                | 91                              |                             | 320           |               |                                  |                                      |
|     | 1.13 | OÚ / IBV                | 9                               |                             | 49            |               |                                  |                                      |
|     | 1.20 | OÚ / HBV                | 38                              |                             | 150           |               |                                  |                                      |
|     |      |                         |                                 | Σ                           | 556           |               |                                  | TS7 250/2x400<br>preložená           |
|     | 1.21 | OÚ / IBV                | 34                              |                             |               | 138           |                                  |                                      |
|     | 1.22 | OÚ / IBV                | 11                              |                             |               | 57            |                                  |                                      |

Celkový výpočtový výkon

1 958

195