

Tabuľka č. 9 - NÁVRH TRAFOSTANÍC**Navrhované nové trafostanice - VPS – variant I. :**

FPB	Označenie	Potrebný výkon (kW)	Obdobie
FPB 1.3	TS 20/261	155	NO
FPB 1.6, 1.9, 1.15	TS 21/261	374	NO
FPB 1.7	TS 22/261	90	NO
FPB 1.10, 1.11 , 1.17, 1.30, 1.31, 1.33, 1.34	TS 23/261	646	NO
FPB 1.16, 1.20 , 1.21	TS 24/261	162	NO
FPB 1.25	TS 20/378	podľa potreby pre technológiu	NO
FPB 1.26	TS 25/261	77	NO
FPB 1.27	TS 26/261	311	NO
FPB 1.28	TS 20/378	podľa potreby pre technológiu	NO
FPB 2.1, 2.14, 2.15	TS 27/261	108	NO
FPB 2.6, 2.7, 2.8, 2.9	TS 28/261	502	NO
FPB 2.12, 2.13	TS 29/261	73	NO

Navrhované nové trafostanice – VPS - variant II. :

FPB	Označenie	Potrebný výkon (kW)	Obdobie
FPB 1.3	TS 20/261	128	NO
FPB 1.6, 1.9, 1.15	TS 21/261	85	NO
FPB 1.10, 1.11 , 1.17, 1.30, 1.31, 1.33, 1.34	TS 23/261	308	NO
FPB 1.20 , 1.21	TS 24/261	51	NO
FPB 1.25	TS 20/378	podľa potreby pre technológiu	NO
FPB 1.26	TS 25/261	77	NO
FPB 1.27	TS 26/261	311	NO
FPB 1.28	TS 20/378	podľa potreby pre technológiu	NO
FPB 1.29	TS 20/378	38	NO
FPB 2.1, 2.2, 2.14	TS 27/261	108	NO
FPB 2.7, 2.8, 2.9	TS 28/261	426	NO
FPB 2.11, 2.12, 2.13	TS 29/261	73	NO